





Control Modes

- Indexer, Point-to-Point, PVT
- Camming, Gearing
- Position, Velocity, Torque

Command Interface

- CANopen over EtherCAT (CoE)
- ASCII and discrete I/O
- Stepper commands
- ±10V position/velocity/torque (2 inputs)
- PWM velocity/torque command
- Master encoder (Gearing/Camming)

Communications

- EtherCAT
- RS-232

Accessories

- External regen resistors
- External edge filter

Feedback

- Digital quad A/B encoder
- EnDat, Hiperface, BiSS, SSI, Yaskawa & Panasonic encoders
- Aux. encoder / encoder out
- Analog sin/cos encoder
- Resolver option
- · Digital Halls

Safety Disable

- Two active inputs enable power stage
- One output confirms power stage status

I/O Digital

• 15 inputs, 6 outputs

I/O Analog

- 2, 16 bit inputs
- 1, 12 bit output

Dimensions: in [mm]

• 7.9 x 5.5 x 2.3 [202 x 139 x 52]





Model	Vac	Ic	Ip
REL-230-18	100 - 240	6	18
REL-230-36	100 - 240	12	36
REL-230-40	100 - 240	20	40

Add -R for resolver feedback option.

DESCRIPTION

REL set new levels of performance, connectivity, and flexibility. Ethernet based EtherCAT operates in CANopen over EtherCAT mode (CoE). A wide range of absolute interfaces are built-in including EnDat, Hiperface, and BiSS.

High resolution A/D converters ensure optimal current loop performance. Both isolated and high-speed non-isolated I/O are provided. For safety critical applications, redundant power stage enable inputs can be employed.

Harmonic Drive LLC, 247 Lynnfield Street, Peabody, MA 01960 Tel: 978.532.1800 Fax: 978.532.9406 Web: www.harmonicdrive.net 800.921.3332 Page 1 of 25







GENERAL SPECIFICATIONS

Test conditions: Wye connected load: 2 mH line-line. Ambient temperature = 25 °C. Power input = 230 Vac, 60 Hz, 1 Ø

MODEL	REL-230-	-18	REL-230-36	REL-230-40	
OUTPUT CURRENT			0.5 (0.5 -:		
Peak Current	18 (12.7	7)	36 (25.5)	40 (28.3)	Adc (Arms, sinusoidal)
Peak time Continuous current (Not	1 e 1) 6 (4.24)	1 12 (8 5)	1 20 (14.1)	s Adc (Arms, sinusoidal)
·	e 1) 0 (4.24)	12 (0.3)	20 (14.1)	Auc (Airiis, Siliusoluai)
INPUT POWER Mains voltage, phase, frequency	loncy		100~240		Vac, ±10%, 1 Ø or 3 Ø, 47∼63 Hz
Mains current			20		Arms
+24 Vdc Control power		— +20 to -	+32 Vdc, 500 mA	max ———	Required for operation
DIGITAL CONTROL			,		'
Digital Control Loops				00% digital loop contr	
Sampling rate (time)		Current loc	op։ 16 kHz (62.5 բ	is), Velocity & position	loops: 4 kHz (250 μs)
Bus voltage compensation				tage do not affect ban	dwidth
Minimum load inductance		200 µH line	e-iiiie		
COMMAND INPUTS Distributed Control Mode					
CANopen over EtherCAT (C	nE)	Position Ve	elocity Torque Ho	mina Profile Interno	lated Profile, and Cyclic Synchronous modes
Stand-alone mode	.OL)	r osicion, v	ciocity, forque, fic	ming, Frome, interpo	idea Frome, and Cyche Synchronous modes
Analog torque, velocity, po	sition reference	±10 Vdc, 1	L6 bit resolution	Dedicated	l differential analog input
Digital position reference			ction, CW/CCW		ommands (2 MHz maximum rate)
		Quad A/B I			sec, 8 Mcount/sec (after quadrature)
Digital torque & velocity re	ference	PWM , Pola	arity		% - 100%, Polarity = 1/0
		PWM 50%	ency range		0% ±50%, no polarity signal required nimum, 100 kHz maximum
			num pulse width	220 ns	iiiidiii, 100 kiiz iiidxiiidiii
Indexing		Up to 32 p	rograms can be la	unched from inputs or	ASCII commands.
Camming		Up to 10 C	AM tables can be	stored in flash memor	у
DIGITAL INPUTS					
Number	15				
[IN1,2]					1.25 Vdc, Vin-HI >= 3.5 Vdc,
[TN26]					pull-up to +5 Vdc or pull-down to ground nable as 4 single-ended, or 2 differential
[IN3~6]					7 Vdc, Vhysteresis = 400 mVdc
					200 mVdc, Vhysteresis = ±200 mVdc
[IN7~14]					of 4 with common for each group
[ENCFLT]	Encoder fault; s	ame electrica	al specs as [IN1,2	,15] except 10 kΩ fixe	ed pull-up to +5 Vdc
ANALOG INPUTS					
Number	3				
[AIN1~2]			input impedance,		/da 10 hit wasslution
[AIN3]	Single-ended, n	notor temper	ature sensor, 4.99	kW pulled-up to +5 \	/dc, 12-bit resolution
DIGITAL OUTPUTS	6				
Number [OUT1~2]	6 Current-sinking	MOSEET with	h 1 kO nullun to +	5 Vdc through diode	
[0011-2]				de required if driving	inductive loads
[OUT3]	High-speed CMC	OS buffer, ±3	32 mA		
[OUT4~5]				ack diodes, 50 mA ma	
[OUT6]	Motor brake con	trol: opto-is	olated, current-sir	king with flyback dioc	le to +24 Vdc, 1 Adc max
ANALOG OUTPUT					
Number	1				
Range	±5 Vdc single-e	naea, 12-bit	resolution		
MULTI-MODE ENCODER PORT	Cocondom, digit	al auadratur	o opendor (A /A I	2 /P V /V) 121 0 to	rminating registers
As Input			rature (4.5 M-lines	3, /B, X, /X), 121 Ω te	rminating resistors
As Output					96 lines (65,536 counts) per rev
7.5 Gatpat					gital quad A/B/X primary encoder
			X3032 differential		, , , , ,
RS-232 PORT					
Signals				style modular connect	
Mode	,		nunication port for	drive setup and conti	ol, 9,600 to 115,200 Baud
Protocol	Binary and ASCI	II formats			
ETHERCAT PORTS					
Format	Dual RJ-45 rece				
Protocol	EtherCAT, CANo	pen over Eth	ercai (COE)		
STATUS INDICATORS	Bicolog LED at the	o status in di	icated by salar are	d blinking or non lettel	ving condition
Drive Status NET Status				d blinking or non-blinl	king condition les to CAN Indicator Specification 303-3
5V OUTPUT	DICOIOI LLD, Stai	Lus of LuielC	ani bus illulcateu	by color and billik COC	ies to early indicator specification 303-3
JV GOIFOI	Two independen	t 5 Vdc @ 40	00 mA outputs: J8	-20 and 110-6 17	
NOTES:	1440 maepenaen	. J Vac @ 40	o ma outputs. 10	20 ana 310 0,17	
NUTES:					

- 1. Heatsinking and/or forced-air cooling is required for continuous output power rating 2. Brake[OUT4] is programmable as motor brake, or as general purpose digital output

Harmonic Drive LLC, 247 Lynnfield Street, Peabody, MA 01960 Tel: 978.532.1800 Fax: 978.532.9406 Web: www.harmonicdrive.net 800.921.3332 Page 2 of 25



EtherCAT



REGENERATION

Operation Internal solid-state switch drives external regen resistor (see Ordering Guide for types)

Cut-In Voltage +HV > 390 Vdc Regen output is on, (optional external) regen resistor is dissipating energy Drop-Out Voltage +HV < 380 Vdc Regen output is off, (optional external) regen resistor not dissipating energy

±2 Vdc For either Cut-In or Drop-Out voltage Tolerance

PROTECTIONS

Mains power loss Interruption or loss of AC power is detected

HV Overvoltage Drive PWM outputs turn off until +HV is less than overvoltage +HV > 400 VdcHV Undervoltage +HV < 60 Vdc Drive PWM outputs turn off until +HV is greater than undervoltage Drive over temperature IGBT > 80 °C ±3 °C Drive PWM outputs turn off until IGBT temperature is below threshold

Output to output, output to ground, internal PWM bridge faults, regen resistor fail-shorts Short circuits

I2T Current limiting

Programmable: continuous current, peak current, peak time
Drive shuts down when motor over-temperature switch changes to high-resistance state, or opens Motor over temperature Feedback power loss

Fault occurs if feedback is removed or +5 V is <85% of normal

MECHANICAL & ENVIRONMENTAL

Size 7.55 in (191,8 mm) X 5.57 in (141,5 mm) X 2.57 in (65,3 mm)

Weight 3.0 lb (1.36 kg) for drive without heatsink

3.1 lb (1.40 kg) for XEL-HS heatsink, 1.86 lb (0.84 kg) for XEL-HL heatsink 0 to +45 °C operating, -40 to +85 °C storage

Ambient temperature

0% to 95%, non-condensing Humidity

Contaminants Pollution degree 2

Vibration $2 g \text{ peak}, 10 \sim 500 \text{ Hz (sine)}, IEC60068-2-6$ 10 g, 10 ms, half-sine pulse, IEC60068-2-27 IEC68-2: 1990 Shock

Environment

Heat sink and/or forced air cooling required for continuous power output Cooling

AGENCY STANDARDS CONFORMANCE

CISPR 11 (1997) Edition 2/Amendment 2: EN 55011: 1998

Limits and Methods of Measurement of Radio Disturbance Characteristics of Industrial, Scientific, and

Medical (ISM) Radio Frequency Equipment


EN 61000-6-1: 2001 Electromagnetic Compatibility Generic Immunity Requirements

Following the provisions of EC Directive 89/336/EEC:

EN 61010-1 2nd Ed.: 2004 Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory use

Following the provisions of EC Directive 2006/95/EC:

UL 508C 3rd Ed.: 2002 UL Standard for Safety for Power Conversion Equipment



Harmonic Drive LLC, 247 Lynnfield Street, Peabody, MA 01960 Web: www.harmonicdrive.net

Fax: 978.532.9406 Tel: 978.532.1800 800.921.3332 Page 3 of 25







FEEDBACK SPECIFICATIONS

DIGITAL QUAD A/B ENCODER	
Type	Quadrature, differential line driver outputs
Signals	A, /A, B, /B, (X, /X, index signals optional)
Frequency	5 MHz line frequency, 20 MHz quadrature count frequency
ANALOG ENCODER	
Туре	Sin/cos/index, differential line driver outputs, 0.5 Vpeak-peak (1.0 Vpeak-peak differential) centered about 2.5 Vdc typical. Common-mode voltage 0.25 to 3.75 Vdc
Signals	Sin(+), $sin(-)$, $cos(+)$, $cos(-)$, $index(+)$, $index(-)$
Frequency	230kHz maximum line (cycle) frequency
Interpolation	10 bits/cycle (1024 counts/cycle)
DIGITAL HALLS	
Туре	Digital, single-ended, 120° electrical phase difference
Signals	U, V, W
Inputs	10 kW pullups to +5 Vdc, 1 μ s RC filter to Schmitt trigger inverters
MULTI-MODE ENCODER PORT	
As Input	Secondary digital quadrature encoder (A, /A, B, /B, X, /X), 121 Ω terminating resistors
	18 M-counts/sec, post-quadrature (4.5 M-lines/sec)
As Emulated Output	Quadrature encoder emulation with programmable resolution to 4096 lines (65,536 counts) per rev
	from analog sin/cos encoders or resolvers.
	A, /A, B, /B, X, /X, from MAX3032 differential line driver
As Buffered Output	Digital encoder feedback signals from primary digital encoder are buffered by MAX3032 line driver
RESOLVER (-R OPTION)	
Туре	Brushless, single-speed, 1:1 to 2:1 programmable transformation ratio
Resolution	14 bits (equivalent to a 4096 line quadrature encoder)
Reference frequency	7.5 kHz
Reference voltage	2.8 Vrms, auto-adjustable by the drive to maximize feedback
Reference maximum current	= * * · · · · ·
Maximum RPM	10,000+
ENCODED DOWED CLIDDLIES	

ENCODER POWER SUPPLIES

Number

Ratings Protection

2 +5 Vdc @ 400 mA from J10-6 and J8-20 Current-limited to 750 mA @ 1 Vdc if overloaded Encoder power developed from +24 Vdc so position information is not lost when AC mains power is removed

Harmonic Drive LLC, 247 Lynnfield Street, Peabody, MA 01960 Tel: 978.532.1800 Fax: 978.532.9406 Web: www.harmonicdrive.net 800.921.3332 Page 4 of 25







ETHERCAT COMMUNICATIONS


EtherCAT is the open, real-time Ethernet network developed by Beckhoff based on the widely used 100BASE-TX cabling system. EtherCAT enables high-speed control of multiple axes while maintaining tight synchronization of clocks in the nodes. Data protocol is CANopen over EtherCAT (CoE) based on DSP-402 for motion control devices.

ETHERCAT CONNECTIONS

Dual RJ-45 sockets accept standard Ethernet cables. The IN port connects to a master, or to the OUT port of a device that is 'upstream', between the REL and the master. The OUT port connects to 'downstream' nodes. If REL is the last node on a network, only the IN port is used. No terminator is required on the OUT port.

J7: EtherCAT PORTS

RJ-45 receptacles, 8 position, 4 contact



PIN	SIGNAL
1	TX+
2	TX-
3	RX+
6	RX-

ETHERCAT LEDS (ON J7)

Green and yellow LEDs indicate the state of the EtherCAT interface: Green is the "Link" indicator: Yellow is the "Activity" indicator:

On = Good Link On = Activity
Off = No Link Blinking Off = No Activity

NET STATUS LED (ON J6)

A bi-color LED indicates the state of the EtherCAT bus.

Green and red colors alternate, and each color has a separate meaning:

Green is the "RUN" or EtherCAT State Machine: Red is the "ERR" indicator: = INIT state Invalid configuration Blinking PRE-OPERATIONAL Blinking = Single Flash Unsolicited state change SAFE-OPERATIONAL Double Flash = Single Flash = Application watchdog timeout On **OPERATIONAL**

AMP STATUS LED

A bi-color LED gives the state of the Xenus Plus drive.

Colors do not alternate, and can be solid ON or blinking:

Green/Solid = Drive OK and enabled. Will run in response to reference inputs

or EtherCAT commands.

Green/Slow-Blinking = Drive OK but NOT-enabled. Will run when enabled.

Green/Fast-Blinking = Positive or Negative limit switch active.

Drive will only move in direction not inhibited by limit switch.

Red/Solid = Transient fault condition. Drive will resume operation when fault is removed.

Red/Blinking = Latching fault. Operation will not resume until drive is Reset.

EtherCAT ADDRESS (STATION ALIAS)

In an EtherCAT network, slaves are automatically assigned addresses based on their position in the bus. But when the device must have a positive identification that is independent of cabling, a Station Alias is needed. In the REL, this is provided by two 16-position rotary switches with hexadecimal encoding. These can set the address of the drive from $0x01\sim0xFF$ ($1\sim255$ decimal). The chart shows the decimal values of the hex settings of each switch.


Example 1: Find the switch settings for decimal address 107:

1) Find the highest number under S1 that is less than 107 and set S1 to the hex value in the same row:

96 < 107 and 112 > 107, so S1 = 96 = Hex 6

2) Subtract 96 from the desired address to get the decimal value of switch S2 and set S2 to the Hex value in the same row:

S2 = (107 - 96) = 11 = Hex B



EtherCAT Address Switch Decimal values

	S1	S2
HEX	DE	C
0	0	0
1	16	1
2	32	2
3	48	3
4	64	4
5	80	5
6	96	6
7	112	7
8	128	8
9	144	9
Α	160	10
В	176	11
С	192	12
D	208	13
E	224	14
F	240	15

Harmonic Drive LLC, 247 Lynnfield Street, Peabody, MA 01960 Tel: 978.532.1800 Fax: 978.532.9406 Web: www.harmonicdrive.net 800.921.3332 Page 5 of 25








COMMUNICATIONS

RS-232 COMMUNICATIONS

REL is configured via a three-wire, full-duplex DTE RS-232 port that operates from 9600 to 115,200 Baud, 8 bits, no parity, and one stop bit. Signal format is full-duplex, 3-wire, DTE using RxD, TxD, and Gnd. Connections to the REL RS-232 port are through J7, an RJ-11 connector. The REL Serial Cable Kit (SER-CK) contains a modular cable, and an adapter that connects to a 9-pin, Sub-D serial port connector (COM1, COM2, etc.) on PC's and compatibles.

SER-CK SERIAL CABLE KIT

The SER-CK provides connectivity between a D-Sub 9 male connector and the RJ-11 connector on the REL. It includes an adapter that plugs into the COM1 (or other) port of a PC and uses common modular cable to connect to the REL. The connections are shown in the diagram below.



J6: RS-232 PORT

RJ-11 receptacle, 6 position, 4 contact



PIN	SIGNAL
2	RxD
3,4	Gnd
5	Txd

ASCII COMMUNICATIONS

The HDLLC ASCII Interface is a set of ASCII format commands that can be used to operate and monitor HDLLC DDP, DEP, RTL AND REL series amplifiers over an RS-232 serial connection. For instance, after basic amplifier configuration values have been programmed using HDM, a control program can use the ASCII Interface to:

- Enable the amplifier in Programmed Position mode.
- · Home the axis.
- Issue a series of move commands while monitoring position, velocity, and other run-time variables.

Additional information can be found in the ASCII Programmers Guide on the HDLLC website: http://www.harmonicdrive.net/spport/documentdownloads/

Harmonic Drive LLC, 247 Lynnfield Street, Peabody, MA 01960 Tel: 978.532.1800 Fax: 978.532.9406 Web: www.harmonicdrive.net 800.921.3332 Page 6 of 25







SAFE-OFF

DESCRIPTION

The REL has a safety feature that is designed to function under the protocol of EN 954-1. Two opto-couplers are provided which, when de-energized, prevent the upper and lower devices in the PWM outputs from being operated by the DSP. This provides a positive OFF capability that cannot be overridden by the DSP, its' firmware, or associated hardware components. When the opto-couplers are activated (current is flowing in the input diodes), the DSP can control the operation and on/off state of the PWM outputs.


FUNCTIONAL DIAGRAM

In order for the PWM outputs of the REL to be activated, current must be flowing through both opto-couplers that are connected to the ENH and ENL terminals of J5, and the drive must be in an ENABLED state. The LED outputs on J5 connect an opto-coupler to an external LED and will conduct current through the LED to light it whenever the PWM outputs can be activated, or the drive is in a diagnostic state. When the LED opto-coupler is OFF, the drive is in a Safe state and the PWM outputs cannot be activated to drive a motor.


SAFE-OFF OVERRIDE

The diagram below shows connections that will energize both ENH and ENL opto-couplers. When this is done the SAFE-OFF feature is defeated and control of the output PWM stage is under control of the DSP. This is the operating mode of CC drives that don't have the SAFE-OFF feature.

FUNCTIONAL DIAGRAM



SAFETY CONNECTOR



J5 SIGNALS

PIN	SIGNAL	PIN	SIGNAL
1	Frame Gnd	6	Enable LED(+)
2	Safe Enable HI(+)	7	Enable LED(-)
3	Safe Enable HI(-)	8	24 Vdc Common
4	Safe Enable LO(+)	9	+24 Vdc Input
5	Safe Enable LO(-)		

Harmonic Drive LLC, 247 Lynnfield Street, Peabody, MA 01960 Tel: 978.532.1800 Fax: 978.532.9406 Web: www.harmonicdrive.net 800.921.3332 Page 7 of 25







COMMAND INPUTS

NON-ISOLATED DIGITAL INPUTS

Inputs [IN1~2] are 24V tolerant

These are high-speed types with pull-up resistors to +5 Vdc and 1 μs RC filters when driven by active sources. The active level is programmable on each input. Input [IN1] is dedicated to the drive enable function. The remaining inputs [IN2 \sim IN14] have programmable functions. Input [IN11] is set up for the motor overtemperature function and connects to the feedback connector J10. If not used as the Motemp input it can be programmed for other functions. All of the inputs can operate from +5 to +24 Vdc sources.

HS Inputs [IN1~2] 24 Vdc max +5.0 V 10k 74HC2G14 IN2] 100pF


DIGITAL INPUTS [IN3~6]


These inputs have all the programmable functions of the GP inputs plus these additional functions on [IN8] & [IN9] which can be configured as single-ended or differential:

- PWM 50%, PWM & Direction for Velocity or Current modes
- Pulse/Direction, CU/CD, or A/B Quad encoder inputs for Position or Camming modes

SINGLE-ENDED 12 Vdc max

DIFFERENTIAL 12 Vdc max





Tel: 978.532.1800

800.921.3332

Fax: 978.532.9406

Page 8 of 25









OPTO-ISOLATED DIGITAL INPUTS

These inputs have all the programmable functions of the GP inputs plus opto-isolation. There are two groups of four inputs, each with its' own common terminal. Grounding the common terminal configures the inputs to work with current-sourcing outputs from controllers like PLC's. When the common terminal is connected to ± 24 V, then the inputs will be activated by current-sinking devices such as NPN transistors or N-channel MOSFETs. The minimum ON threshold of the inputs is ± 15 Vdc.

[IN7~10] ±30 Vdc max


IN11~14 ±30 Vdc max





ANALOG INPUTS

Two differential analog inputs with ± 10 Vdc range have programmable functions. As a reference input [AIN1] can take position/velocity/torque commands from a controller. A second input [AIN2] is programmable for other functions. The ratio of drive output current or velocity vs. reference input voltage is programmable.




Harmonic Drive LLC, 247 Lynnfield Street, Peabody, MA 01960 Web: www.harmonicdrive.net Tel: 978.532.1800 Fax: 978.532.9406 800.921.3332 Page 9 of 25

OUTPUTS


DIGITAL OUTPUTS [OUT1], [OUT2]

These are open-drain MOSFETs with 1 k Ω pull-up resistors in series with a diode to +5 Vdc. They can sink up to 1 Adc from external loads operating from power supplies to +30 Vdc. The output functions are programmable. The active state of the outputs is programmable to be on or off. When driving inductive loads such as a relay, an external fly-back diode is required.

The internal diode in the output is for driving PLC inputs that are opto-isolated and connected to +24 Vdc. The diode prevents conduction from +24 Vdc through the 1 k Ω resistor to +5 Vdc in the drive. This could turn the PLC input on, giving a false indication of the drive output state.




HIGH SPEED OUTPUT [OUT3] 5V CMOS




BRAKE OUTPUT [OUT6]

This output is an open-drain MOSFET with an internal flyback diode connected to the +24 Vdc input. It can sink up to 1A from a motor brake connected to the +24 Vdc supply. The operation of the brake is programmable with HDM. It can also be programmed as a general-purpose digital output.




OPTO-ISOLATED OUTPUTS [OUT4,5] 30 Vdc max



ANALOG OUTPUT

The analog output is programmable and has an output voltage range of ± 5 Vdc. An op-amp buffers the output of a 12-bit D/A converter.



Harmonic Drive LLC, 247 Lynnfield Street, Peabody, MA 01960 Tel: 978.532.1800 Fax: 978.532.9406 Web: www.harmonicdrive.net 800.921.3332 Page 10 of 25







MOTOR CONNECTIONS

Motor connections are of three types: phase, feedback, and thermal sensor. The phase connections carry the drive output currents that drive the motor to produce motion. A thermal sensor that indicates motor overtemperature is used to shut down the drive to protect the motor. Feedback can be digital quad A/B encoder, analog sin/cos encoder, resolver or digital Halls, depending on the version of the drive.

QUAD A/B ENCODER WITH FAULT PROTECTION

Encoders with differential line-driver outputs provide incremental position feedback via the A/B signals and the optional index signal (X) gives a once per revolution position mark. The MAX3097 receiver has differential inputs with fault protections for the following conditions:


Short-circuits line-line: This produces a near-zero voltage between A & /A which is below the differential fault threshold.

Open-circuit condition: The 121W terminator resistor will pull the inputs together if either side (or both) is open. This will produce the same fault condition as a short-circuit across the inputs.

Low differential voltage detection: This is possible with very long cable runs and a fault will occur if the differential input voltage is < 200mV.


 $\pm 15 kV$ ESD protection: The 3097E has protection against high-voltage discharges using the Human Body Model.

Extended common-mode range: A fault occurs if the input common-mode voltage is outside of the range of $\,$ -10V to +13.2V




ANALOG SIN/COS INCREMENTAL ENCODER

The sin/cos/index inputs are differential with $121~\Omega$ terminating resistors and accept 1 Vp-p signals in the format used by incremental encoders with analog outputs, or with Linear motors.



RESOLVER (-R MODELS)

Connections to the resolver should be made with shielded cable that uses three twisted-pairs. Once connected, resolver set up, motor phasing, and other commissioning adjustments are made with HDM software. There are no hardware adjustments.



Harmonic Drive LLC, 247 Lynnfield Street, Peabody, MA 01960 Tel: 978.532.1800 Fax: 978.532.9406 Web: www.harmonicdrive.net 800.921.3332 Page 11 of 25








MOTOR CONNECTIONS (CONT'D)


SSI ABSOLUTE ENCODER

The SSI (Synchronous Serial Interface) is an interface used to connect an absolute position encoder to a motion controller or control system. The XEL drive provides a train of clock signals in differential format to the encoder which initiates the transmission of the position data on the subsequent clock pulses. The polling of the encoder data occurs at the current loop frequency (16 kHz). The number of encoder data bits and counts per motor revolution are programmable. The hardware bus consists of two signals: SCLK and SDATA. Data is sent in 8 bit bytes, LSB first. The SCLK signal is only active during transfers. Data is clocked out on the falling edge and clock in on the rising edge of the Master.



ENDAT ABSOLUTE ENCODER

The EnDat interface is a Heidenhain interface that is similar to SSI in the use of clock and data signals, but which also supports analog sin/cos channels from the same encoder. The number of position data bits is programmable as is the use of sin/cos channels. Use of sin/cos incremental signals is optional in the EnDat specification.



BISS ABSOLUTE ENCODER

BiSS is an - Open Source - digital interface for sensors and actuators. BiSS refers to principles of well known industrial standards for Serial Synchronous Interfaces like SSI, AS-Interface® and Interbus® with additional options.

Serial Synchronous Data Communication Cyclic at high speed

2 unidirectional lines Clock and Data

Line delay compensation for high speed data transfer Request for data generation at slaves


Request for data generation at slaves Safety capable: CRC, Errors, Warnings

Bus capability incl. actuators

Bidirectional


BiSS B-protocol: Mode choice at each cycle start

BiSS C-protocol: Continuous mode



NIKON-A ABSOLUTE ENCODER

The Nikon A interface is a serial, half-duplex type that is electrically the same as $\ensuremath{\mathsf{RS-485}}$



Harmonic Drive LLC, 247 Lynnfield Street, Peabody, MA 01960 Tel: 978.532.1800 Fax: 978.532.9406 Web: www.harmonicdrive.net 800.921.3332 Page 12 of 25








MOTOR CONNECTIONS (CONT'D)


MOTOR PHASE CONNECTIONS

The drive output is a three-phase PWM inverter that converts the DC buss voltage (+HV) into three sinusoidal voltage waveforms that drive the motor phase-coils. Cable should be sized for the continuous current rating of the motor. Motor cabling should use twisted, shielded conductors for CE compliance, and to minimize PWM noise coupling into other circuits. The motor cable shield should connect to motor frame and the drive frame ground terminal (J2-1) for best results.



DIGITAL HALL SIGNALS


Hall signals are single-ended signals that provide absolute feedback within one electrical cycle of the motor. There are three of them (U, V, & W) and they may be sourced by magnetic sensors in the motor, or by encoders that have Hall tracks as part of the encoder disc. They typically operate at much lower frequencies than the motor encoder signals, and are used for commutation-initialization after startup, and for checking the motor phasing after the amplifier has switched to sinusoidal commutation.



* Alternate Sgnd connections on J10 are pins 16, 25, 26

MOTOR TEMPERATURE SENSOR


Analog input Motemp, is for use with a motor overtemperature switch or sensor. The input voltage goes through a low-pass filter to a 12-bit A/D converter. The active level of the input, Vset, is programmable generate an over-temperature fault if the input voltage is <Vset, or >Vset.



* Alternate Sqnd connections on J10 are pins 16, 25, 26

ENCODER FAULT

A high-speed (HS) non-isolated input with a pull-up resistor to +5 Vdc and 1 μs RC filter when driven by active sources. The active level is programmable. For encoders that output a FAULT signal in addition to the other position data signals



Harmonic Drive LLC, 247 Lynnfield Street, Peabody, MA 01960 Tel: 978.532.1800 Fax: 978.532.9406 Web: www.harmonicdrive.net 800.921.3332 Page 13 of 25








MOTOR CONNECTIONS (CONT'D)

MULTI-MODE ENCODER PORT

This port consists of three differential input/output channels that take their functions from the Basic Setup of the drive. With quad A/B encoder feedback, the port works as an output, buffering the signals from the encoder. With resolver or sin/cos encoder versions, the feedback is converted to "emulated" quad A/B/X signals with programmable resolution. These signals can then be fed back to an external motion controller that closes the position or velocity loops. As an input, the port can take quad A/B signals to produce a dual-loop position control system or use the signals as master-encoder commands in camming mode. In addition, the port can take stepper command signals (CU/CD or Pulse/Direction) in differential format.


AS BUFFERED OUTPUTS FROM A DIGITAL QUADRATURE PRIMARY ENCODER

When using a digital quadrature feedback encoder, the A/B/X signals drive the multi-mode port output buffers directly. This is useful in systems that use external controllers that also need the motor feedback encoder signals because these now come from J8, the Control connector. In addition to eliminating "Y" cabling where the motor feedback cable has to split to connect to both controller and motor, the buffered outputs reduce loading on the feedback cable that could occur if the motor encoder had to drive two differential inputs in parallel, each with it's own 121 ohm terminating resistor.




AS EMULATED QUAD A/B/X ENCODER OUTPUTS FROM AN ANALOG SIN/COS FEEDBACK ENCODER

Analog sin/cos signals are interpolated in the drive with programmable resolution. The incremental position data is then converted back into digital quadrature format which drives the multi-mode port output buffers. Some analog encoders also produce a digital index pulse which is connected directly to the port's output buffer. The result is digital quadrature A/B/X signals that can be used as feedback to an external control system.




AS A MASTER OR CAMMING ENCODER INPUT FROM A DIGITAL QUADRATURE ENCODER

When operating in position mode the multi-mode port can accept digital command signals from external encoders. These can be used to drive cam tables, or as master-encoder signals when operating in a master/slave configuration.



AS DIGITAL COMMAND INPUTS IN PULSE/DIRECTION, PULSE-UP/PULSE-DOWN, OR DIGITAL QUADRATURE ENCODER FORMAT

The multi-mode port can also be used when digital command signals are in a differential format. These are the signals that typically go to single-ended inputs. But, at higher frequencies these are likely to be differential signals in which case the multi-mode port can be used.



Fax: 978.532.9406

Page 14 of 25

Harmonic Drive LLC, 247 Lynnfield Street, Peabody, MA 01960 Tel: 978.532.1800
Web: www.harmonicdrive.net 800.921.3332








Fax: 978.532.9406

Page 15 of 25

Quad A/B Encoder

MOTOR CONNECTIONS (CONT'D)



NOTES:

1) The total output current from the +5 Vdc supply to J7-20 cannot exceed 400 mAdc

Tel: 978.532.1800

800.921.3332


2) Line filter is required for CE



Fax: 978.532.9406

Page 16 of 25

MOTOR CONNECTIONS (CONT'D)



NOTES:

1) The total output current from the +5 Vdc supply to J7-20 cannot exceed 400 mAdc

Tel: 978.532.1800

800.921.3332

2) Line filter is required for CE








Fax: 978.532.9406

Page 17 of 25

Resolver i

MOTOR CONNECTIONS (CONT'D)



NOTES:

1) The total output current from the +5 Vdc supply to J7-20 cannot exceed 400 mAdc

Tel: 978.532.1800

800.921.3332

2) Line filter is required for CE







Quad A/B Encoder =



WARNING: Hazardous voltages exist on connections to J1, J2, & J3 when power is applied, and for up to 30 seconds after power is removed.



J1 CABLE CONNECTOR:

Wago: 51118287 or 721-204/026-045/RN01-0000 Euro-style 7,5 mm pluggable female terminal block

with preceding ground receptacle Cable: AWG 12, 600 V recommended

for REL-230-36-R and REL-230-40-R models,

AWG 14, 600V for REL-230-18-R

Shielded cable required for CE compliance

Signal	Pin
Mains Input L3	4
Protective Ground	3
Mains Input L2	2
Mains Input L1	1

J2 MOTOR OUTPUTS

Signal	Pin
Motor Phase U	4
Motor Phase V	3
Motor Phase W	2
Cable Shield	1

J2 CABLE CONNECTOR:

Wago: 51118008 or 721-104/026-047/RN01-0000 Euro-style 5,0 mm pluggable female terminal block

Cable: AWG 12, 600 V recommended

for REL-230-36-R and REL-230-40-R models,

AWG 14, 600V for REL-230-18-R

Shielded cable required for CE compliance

J3 CABLE CONNECTOR:

Wago: 51111277 or 721-605/000-044/RN01-0000 Euro-style 5,0 mm pluggable male terminal block

Cable: AWG 12, 600 V recommended

for REL-230-36-R and REL-230-40-R models,

AWG 14, 600V for REL-230-18-R

Shielded cable required for CE compliance

J3 REGEN RESISTOR

Signal	Pin
Regen Resistor	1
No Connection	2
Regen Resistor	3
No Connection	4
Cable Shield	5

WIRE INSERTION/EXTRACTION TOOL:

Used on J1, J2, J3, & J4 Wago 231-131

ISOLATED CIRCUIT

NOTE: AN EXTERNAL +24 VDC POWER SUPPLY IS REQUIRED FOR OPERATION

J4 CABLE CONNECTOR:

Wago: 51117974 or 721-103/026-047/RN01-0000 Euro-style 5,0 mm pluggable terminal block


J4 +24 VDC & BRAKE

Signal	Pin
+24 Vdc Control Power	3
Brake Output [OUT6]	2
0V (+24 Vdc Return)	1

ISOLATED CIRCUIT

Tel: 978.532.1800

800.921.3332



Fax: 978.532.9406


Page 18 of 25







■ Quad A/B Encoder 🕳



J8 CONTROL SIGNALS

PIN	SIGNAL	PIN	SIGNAL][PIN	SIGNAL
1	Frame Gnd	10	[IN6] HS		19	Signal Gnd
2	[AIN1+]	11	[AIN2+]		20	+5 Vdc Out
3	[AIN1-]	12	[AIN2-]][21	Multi Enc /X2
4	[IN1] GP	13	Multi Enc /S2		22	Multi Enc X2
5	[IN2] GP	14	Multi Enc S2	$\ $	23	Multi Enc /B2
6	[IN3] HS	15	Signal Gnd][24	Multi Enc B2
7	[IN4] HS	16	[OUT1]][25	Multi Enc /A2
8	[IN5] HS	17	[OUT2]		26	Multi Enc A2
9	[AOUT]	18	[OUT3]]		

J8 CABLE CONNECTOR:

High-Density D-Sub male, 26 Position

J9 SECONDARY I/O CONNECTOR

PIN	SIGNAL	PIN	SIGNAL	PIN	SIGNAL
1	Frame Gnd	6	[IN10] GPI	11	[IN14] GPI
2	[COMM_A]	7	[COMM_B]	12	[OUT5+] GPI
3	[IN7] GPI	8	[IN11] GPI	13	[OUT5-] GPI
4	[IN8] GPI	9	[IN12] GPI	14	[OUT4+] GPI
5	[IN9] GPI	10	[IN13] GPI	15	[OUT4-] GPI

J9 CABLE CONNECTOR:

High-Density D-Sub female, 15 Position

J10 FEEDBACK

PIN	SIGNAL	PIN	SIGNAL	PIN	SIGNAL
1	Frame Gnd	10	Enc /B1	19	Sin1(+)
2	Hall U	11	Enc B1	20	Cos1(-)
3	Hall V	12	Enc /A1	21	Cos1(+)
4	Hall W	13	Enc A1	22	Index1(-)
5	Signal Gnd	14	Enc /S1	23	Index1(+)
6	+5 Vdc Out	15	Enc S1	24	Enc Fault
7	Motemp	16	Signal Gnd	25	Signal Gnd
8	Enc /X1	17	+5 Vdc Out	26	Signal Gnd
9	Enc X1	18	Sin1(-)		

J10 CABLE CONNECTOR:

High-Density D-Sub female, 26 Position

J5 SAFETY DISABLE

PIN	SIGNAL	PIN	SIGNAL
1	Frame Gnd	6	Enable LED(+)
2	Safe Enable HI(+)	7	Enable LED(-)
3	Safe Enable HI(-)	8	24 Vdc Common
4	Safe Enable LO(+)	9	+24 Vdc Output
5	Safe Enable LO(-)		

J5 CABLE CONNECTOR:

D-Sub male, 9 Position

Tel: 978.532.1800

800.921.3332







■ Resolver i



WARNING: Hazardous voltages exist on connections to J1, J2, & J3 when power is applied, and for up to 30 seconds after power is removed.



J1 CABLE CONNECTOR:

Wago: 51118287 or 721-204/026-045/RN01-0000 Euro-style 7,5 mm pluggable female terminal block

with preceding ground receptacle Cable: AWG 12, 600 V recommended

for REL-230-36-R and REL-230-40-R models,

AWG 14, 600V for REL-230-18-R

Shielded cable required for CE compliance

J1 MAINS CONNECTIONS

Signal	Pin
Mains Input L3	4
Protective Ground	3
Mains Input L2	2
Mains Input L1	1

J2 MOTOR OUTPUTS

Signal	Pin
Motor Phase U	4
Motor Phase V	3
Motor Phase W	2
Cable Shield	1

J2 CABLE CONNECTOR:

Wago: 51118008 or 721-104/026-047/RN01-0000 Euro-style 5,0 mm pluggable female terminal block

Cable: AWG 12, 600 V recommended

for REL-230-36-R and REL-230-40-R models,

AWG 14, 600V for REL-230-18-R

Shielded cable required for CE compliance

J3 CABLE CONNECTOR:

Wago: 51111277 or 721-605/000-044/RN01-0000 Euro-style 5,0 mm pluggable male terminal block

Cable: AWG 12, 600 V recommended

for REL-230-36-R and REL-230-40-R models,

AWG 14, 600V for REL-230-18-R

Shielded cable required for CE compliance

J3 REGEN RESISTOR

Signal	Pin
Regen Resistor	1
No Connection	2
Regen Resistor	3
No Connection	4
Cable Shield	5

WIRE INSERTION/EXTRACTION TOOL:

Used on J1, J2, J3, & J4 Wago 231-131

ISOLATED CIRCUIT

NOTE: AN EXTERNAL +24 VDC POWER SUPPLY IS REQUIRED FOR OPERATION

J4 CABLE CONNECTOR:

Wago: 51117974 or 721-103/026-047/RN01-0000 Euro-style 5,0 mm pluggable terminal block


J4 +24 VDC & BRAKE

Signal	Pin
+24 Vdc Control Power	3
Brake Output [OUT6]	2
0V (+24 Vdc Return)	1

ISOLATED CIRCUIT

Tel: 978.532.1800

800.921.3332



Fax: 978.532.9406


Page 20 of 25







Resolver



J8 CONTROL SIGNALS

PIN	SIGNAL	PIN	SIGNAL	$\ [$	PIN	SIGNAL
1	Frame Gnd	10	[IN6] HS][19	Signal Gnd
2	[AIN1+]	11	[AIN2+]][20	+5 Vdc Out
3	[AIN1-]	12	[AIN2-]		21	Multi Enc /X2
4	[IN1] GP	13	Multi Enc /S2	$\ [$	22	Multi Enc X2
5	[IN2] GP	14	Multi Enc S2][23	Multi Enc /B2
6	[IN3] HS	15	Signal Gnd		24	Multi Enc B2
7	[IN4] HS	16	[OUT1]][25	Multi Enc /A2
8	[IN5] HS	17	[OUT2]		26	Multi Enc A2
9	[AOUT]	18	[OUT3]]		

J8 CABLE CONNECTOR:

High-Density D-Sub female, 26 Position

J9 SECONDARY I/O CONNECTOR

PIN	SIGNAL	PIN	SIGNAL	PIN	SIGNAL
1	Frame Gnd	6	[IN10] GPI	11	[IN14] GPI
2	[COMM_A]	7	[COMM_B]	12	[OUT5+] GPI
3	[IN7] GPI	8	[IN11] GPI	13	[OUT5-] GPI
4	[IN8] GPI	9	[IN12] GPI	14	[OUT4+] GPI
5	[IN9] GPI	10	[IN13] GPI	15	[OUT4-] GPI

J9 CABLE CONNECTOR:

High-Density D-Sub male, 15 Position

J10 FEEDBACK

PIN	SIGNAL	PIN	SIGNAL	PIN	SIGNAL
1	Frame Gnd	10	Enc /B1	19	Sin1(+) S3
2	Hall U	11	Enc B1	20	Cos1(-) S4
3	Hall V	12	Enc /A1	21	Cos1(+) S2
4	Hall W	13	Enc A1	22	Ref(-) R2
5	Signal Gnd	14	Enc /S1	23	Ref(+) R1
6	+5 Vdc Out	15	Enc S1	24	Enc Fault
7	Motemp	16	Signal Gnd	25	Signal Gnd
8	Enc /X1	17	+5 Vdc Out	26	Signal Gnd
9	Enc X1	18	Sin1(-) S1		

J10 CABLE CONNECTOR:

High-Density D-Sub male, 26 Position

J5 SAFETY DISABLE

PIN	SIGNAL	PIN	SIGNAL
1	Frame Gnd	6	Enable LED(+)
2	Safe Enable HI(+)	7	Enable LED(-)
3	Safe Enable HI(-)	8	24 Vdc Common
4	Safe Enable LO(+)	9	+24 Vdc Output
5	Safe Enable LO(-)		

J5 CABLE CONNECTOR:

D-Sub male, 9 Position

Tel: 978.532.1800

800.921.3332







DRIVE POWER SOURCES

An external +24 Vdc power supply is required, and powers an internal DC/DC converter that supplies all the control voltages for drive operation. Use of an external supply enables EtherCAT communication with the drive when the mains power has been removed.

Power distribution in *REL* is divided into four sections: +24 Vdc, signal, and high-voltage. Each is isolated from the other and all are isolated from the chassis.

EXTERNAL +24 VDC

The primary side of the DC/DC converter operates directly from the external +24 Vdc supply and is isolated from other drive power sections. The Brake output [OUT4] operates in this section and is referenced to the +24 Vdc return (0V). It sinks current from an external load connected to the external +24 Vdc power source.

INTERNAL SIGNAL POWER

The signal power section supplies power for the control circuits as well as logic inputs and outputs. Motor feedback signals such as Halls, encoder, and temperature sensor operate from this power source. All signal circuits are referenced to signal ground. This ground should connect to the control system circuit ground or common so that drive and controller inputs and output voltage levels work properly with each other.

MAINS POWER

Mains power drives the high-voltage section. It is rectified and capacitor-filtered to produce +HV which the PWM stage converts into voltages that drive either three phase brushless or DC brush motors. An internal solid-state switch together with an external power resistor provides dissipation during regeneration when the mechanical energy of the motor is converted back into electrical energy that must be dissipated before it charges the internal capacitors to an overvoltage condition. All the circuits in this section are "hot", that is, they connect directly to the mains and must be considered high-voltages and a shock hazard requiring proper insulation techniques during installation.

GROUNDING


A grounding system has three primary functions: safety, voltage-reference, and shielding. As a safety measure, the primary ground at J1-3 will carry fault-currents from the mains in the case of an internal failure or short-circuit of electronic components. Wiring to this is typically done with the green conductor with yellow stripe using the same gauge wire as that used for the mains. The pin on the drive at J1-3 is longer than the other pins on J1 giving it a first-make, last-break action so that the drive chassis is never ungrounded when the mains power is connected. This wire is a 'bonding' conductor that should connect to an earthed ground point and must not pass through any circuit interrupting devices.

All of the circuits on J1, J2, and J3 are mainsconnected and must never be grounded. The ground terminals at J1-3, J2-1, and J3-5 all connect to the drive chassis and are isolated from all drive internal circuits.

Signal grounding references the drive control circuits to those of the control system. These controls circuits typically have their own earth connection at some point. To eliminate ground-loops it is recommended that the drive signal ground be connected to the control system circuit ground. When this is done the drive signal voltages will be referenced to the same 0 V level as the circuits in the control system. Small currents flow between controller and drive when inputs and outputs interact. The signal ground is the path for these currents to return to their power sources in both controller and drive.


Shields on cables reduce emissions from the drive for CE compliance and protect internal circuits from interference due to external sources of electrical noise. Because of their smaller wire gauge, these should not be used as part of a safety-ground system. Motor cases can be safety-grounded either at the motor, by earthing the frame, or by a grounding conductor in the motor cable that connects to J2-1. This cable should be of the same gauge as the other motor phase cables.

For CE compliance and operator safety, the drive heatplate should be earthed to the equipment frame. An unplated tab is provided on the heatplate (near to J1) for this connection.



REGENERATION

The chart below shows the energy absorption in W·s for a *REL* drive operating at some typical mains voltages. When the load mechanical energy is greater than these values an external regen resistor is available as an accessory.



Harmonic Drive LLC, 247 Lynnfield Street, Peabody, MA 01960 Tel: 978.532.1800 Fax: 978.532.9406 Web: www.harmonicdrive.net 800.921.3332 Page 22 of 25








GROUNDING & SHIELDING FOR CE

Grounding and shielding are the means of controlling the emission of radio frequency energy from the drive so that it does not interfere with other electronic equipment. The use of shielded cables to connect the drive to motors and feedback devices is a way of extending the chassis of the drive out to these devices so that the conductors carrying noise generated by the drive are completely enclosed by a conductive shield.

The process begins at the mains connector of the drive, J1. The ground terminal here has a circle around it indicating that this is the safety or "bonding" ground connection. This should be connected with wire that is the same gauge as that used for the mains. In the case of a short-circuit in the drive the function of this ground connection is to carry the fault current to earth ground until the safety device (fuse or circuit breakers) disconnects the drive from the mains. This connection ensures that the heatplate of the drive remains at earth potential and eliminating a shock hazard that could occur of the chassis were allowed to float to the potential of the mains.

While this connection keeps the heatplate at earth potential the high frequency noise generated by switching circuits in the drive can radiate from the wire used for the safety ground connection. In order to keep the path between the heatplate and earth as short as possible it's also recommended to mount the drive to the equipment panel. An unplated tab on the heatplate is provided for this and will ground the heatplate directly to the equipment frame, further reducing emissions.

The heatplate also connects directly to the frame ground terminals on the motor, feedback, and regen connectors. Note that the ground symbols for these do not have a circle around them which indicates that these are for shielding and not not for safety grounding. Motors and their feedback devices (which are typically in the motor case) should be grounded by mounting to equipment that is grounded as a safety ground. By connecting the shields for these devices at the drive and at the device, the connection is continuous and provides a return path for radio-frequency energy to the drive.



Notes:

- 1) Shielded cables required for CE are shown in the diagram above.
- 2) Line filter required for CE
- 3) Ferrite core required for shielded cable to regen resistor which must be in shielded enclosure.

Harmonic Drive LLC, 247 Lynnfield Street, Peabody, MA 01960 Tel: 978.532.1800 Fax: 978.532.9406 Web: www.harmonicdrive.net 800.921.3332 Page 23 of 25









MAXIMUM OPERATING TEMPERATURE VS HEATSINK TYPE & AIR CIRCULATION

The charts below show maximum ambient temperature vs. continuous output current for the REL Series. The cooling options are no heatsink, standard heatsink, and low-profile heatsink. For each of these the drive can be operated with convection or forced-air cooling.


REL-230-18




REL-230-18




REL-230-36




REL-230-36



REL-230-40



REL-230-40



Harmonic Drive LLC, 247 Lynnfield Street, Peabody, MA 01960 Tel: 978.532.1800 Fax: 978.532.9406 Web: www.harmonicdrive.net 800.921.3332 Page 24 of 25







■ Quad A/B Encoder **—**

REL-230-18	REL with EtherCAT Servo Drive 6/18 Adc		
REL-230-36	REL with EtherCAT Servo Drive 12/36 Adc		
REL-230-40	REL with EtherCAT Servo Drive 20/40 Adc		

Add "-R" to model number for resolver option

ACCESSORIES

	QTY	REF	DESCRIPTION	MANUFACTURERS PART NUMBER
XEL-CK Connector Kit with Solder Cup Connectors for J5, J8, J9 & J10	1	J1	Plug, 4 position, 7.5 mm, female	Wago: 51118287 or 721-204/026-045/RN01-0000
	1	J2	Plug, 4 position, 5.0 mm, female	Wago: 51118008 or 721-104/026-047/RN01-0000
	1	J3	Plug, 5 position, 5.0 mm, male	Wago: 51111277 or 721-605/000-044/RN01-0000
	1	J4	Plug, 3 position, 5.0 mm, female	Wago: 51117974 or 721-103/026-047/RN01-0000
	4	J1~4	Tool, wire insertion & extraction (for J1~4)	Wago: 231-131
	1	J5	Connector, D-Sub, 9-position, male, solder cup	Norcomp: 171-009-103L001
	1		Backshell, D-Sub, RoHS, metallized, for above	Norcomp: 979-009-020R121
	1	ј8	Connector, high-density D-Sub, 26 position, female, solder cup	Norcomp: 180-026-203L001
	1		Backshell, D-Sub, RoHS, metallized, for above	Norcomp: 979-025-020R121
	1	J9	Connector, high-density D-Sub, 15 position, male, solder cup	Norcomp: 180-015-103L001
	1		Backshell, D-Sub, RoHS, metallized, for above	Norcomp: 979-009-020R121
	1	J10	Connector, high-density D-Sub, 26 position, male, solder cup	Norcomp: 180-026-103L001
	1		Backshell, D-Sub, RoHS, metallized, for above	Norcomp: 979-025-020R121
HDM	J5		HDM Drive Configuration Software (CD-ROM)	
SER-CK			RS-232 Cable Kit	

Heatsink Kits for Field Installation (Optional)

XEL-HL Heatsink Kit Low-Profile	1	Heatsink, low-profile
	1	Heatsink thermal material
	4	Heatsink hardware
XEL-HS Heatsink Kit Standard	1	Heatsink, standard
	1	Heatsink thermal material
	4	Heatsink hardware

Regeneration Resistors (Optional)

XTL-RA-03	Regeneration resistor assembly (for REL-230-18), 30 W
XTL-RA-04	Regeneration resistor assembly (for REL-230-36 & REL-230-40 models), 15 W

Edge Filter (Optional)

XTL-FA-01		Edge filter	
Edge Filter Connector Kit XTL-FK	1	Plug, 4 position, 5.0 mm, female	Wago: 51118008 or 721-104/026-047/RN01-0000
	1	Plug, 5 position, 5.0 mm, male	Wago: 51111277 or 721-605/000-044/RN01-0000
	2	Tool, wire insertion & extraction	Wago: 231-131

Example: Order one REL drive, resolver version, 6/18 A with solder-cup connector Kit, HDM CD, serial cable kit and small heatsink fitted at the factory:

 Qty
 Item
 Remarks

 1
 REL-230-18-R-HS
 REL servo drive

 1
 XEL-CK
 Connector Kit

 1
 HDM
 HDM CD

 1
 SER-CK
 Serial Cable Kit

Note: The heatsink can be fitted at the factory by adding an "-HS" or "-HL" to the drive part number to specify the standard or low-profile type. For fitting a heatsink to an drive in the field, complete kits are available (XEL-HS and XEL-HL). These kits contain the heatsink, mounting hardware, and dry-film interface.

Note: Specifications are subject to change without notice Rev 4.02_th 1/08/2013

Harmonic Drive LLC, 247 Lynnfield Street, Peabody, MA 01960 Tel: 978.532.1800 Fax: 978.532.9406 Web: www.harmonicdrive.net 800.921.3332 Page 25 of 25